GOODWE

ES Series (14A) Single-phase Hybrid Inverter (LV)

The GoodWe ES Series is a bi-directional energy storage inverter with the ability to control the flow of energy intelligently. During the day, the PV array generates electricity which can be provided either to the loads, fed into the grid or charge the battery, depending on the economics and setup. The electricity stored can be released when the loads require it during the night, including inductive loads such as air conditioners or refrigerators. Additionally, the power grid can also charge storage devices via the inverter. An all-round intelligent system for maximum energy flexibility.



Charge controller and inverter integrated



Export control (Zero export)



10ms UPS-level Switching



Maximum charge and discharge up to 100A



IP65 dustproof and waterproof

14



Fanless design, long lifespan

GOODWE

Technical Data	GW3648D-ES ^{'5}	GW5048D-ES [™]
Battery Input Data		
Battery Type*1	Li-Ion	Li-Ion
Nominal Battery Voltage (V)	48	48
Battery Voltage Range (V)	40 ~ 60	40 ~ 60
Aax. Continuous Charging Current (A) ^{*1}	75	100
Aax. Continuous Discharging Current (A) ^{*1}	75	100
Nax. Charging Power (W)	3600	4600
/lax. Discharging Power (W)	3600	4600
PV String Input Data		
fax. Input Voltage (V)	580	580
IPPT Operating Voltage Range (V)	125 ~ 550	125 ~ 550
Start-up Voltage (V)	125	125
Jominal Input Voltage (V)	360	360
Ax. Input Current per MPPT (A)	14 / 14	14 / 14
Nax. Short Circuit Current per MPPT (A)	17.5 / 17.5	17.5 / 17.5
Jumber of MPPTs	2	2
Jumber of Strings per MPPT	1	1
AC Output Data (On-grid)		
Jominal Apparent Power Output to Utility Grid (VA) ^{*5}	3680	5000
Ax. Apparent Power Output to Utility Grid (VA)*2	3680	5000
Ax. Apparent Power from Utility Grid (VA)	7360	9200
Iominal Output Voltage (V)	230	230
Iominal AC Grid Frequency (Hz)	50 / 60	50 / 60
Iax. AC Current Output to Utility Grid (A)	16.0 ^{*6}	24.5
Iax. AC Current From Utility Grid (A)	32	40
Power Factor		B leading to 0.8 lagging)
Iax. Total Harmonic Distortion	<3%	<3%
AC Output Data (Back-up)		
Back-up Nominal Apparent Power (VA)	3680	4600
/lax. Output Apparent Power (VA) ^{*3}	3680 (5520@10sec)	4600 (6900@10sec)
Iax. Output Current (A)	16	20
Jominal Output Voltage (V)	230 (±2%)	230 (±2%)
Nominal Output Frequency (Hz)	50 / 60 (±0.2%)	50 / 60 (±0.2%)
Dutput THDv (@Linear Load)	<3%	<3%
Efficiency		
Max. Efficiency	97.6%	97.6%
uropean Efficiency	97.0%	97.0%
Ax. Battery to AC Efficiency	94.0%	94.0%
/IPPT Efficiency	99.9%	99.9%
Protection		
V Insulation Resistance Detection	Integrated	Integrated
Residual Current Monitoring	Integrated	Integrated
V Reverse Polarity Protection	Integrated	Integrated
Inti-islanding Protection	Integrated Integrated	Integrated Integrated
C Short Circuit Protection	Integrated Integrated	Integrated
C Overvoltage Protection	Integrated	Integrated
General Data		
Derating Temperature Range (°C)	-25 ~ +60	-25 ~ +60
Relative Humidity	0 ~ 95%	0 ~ 95%
flax. Operating Altitude (m)	3000	3000
Cooling Method	Natural Convection	Natural Convection
Display	LED & APP	LED & APP
Communication with BMS ^{*4}	RS485; CAN	RS485; CAN
Communication with Meter	RS485	RS485
Communication with Portal	Wi-Fi	Wi-Fi
Veight (kg)	28	30
Dimension (W \times H \times D mm)	516 × 440 × 184	516 × 440 × 184
loise Emission (dB)	<25	<25
opology	Non-isolated	Non-isolated
ngress Protection Rating	IP65	IP65
Igless Flotection halling	11 05	11 00

*1: The actual charge and discharge current also depends on the battery.
*2: 4600 for VDE 0126-1-1 & VDE-AR-N4105 & NRS 097-2-1.
*3: Peak output apparent power can be reached only if PV and battery power is enough.
*4: CAN communication is configured by default. If 485 communication is used, please replace the corresponding communication line.
*5: FOR AUSTRALIA ONLY. Model GW3648D-ES inverters are designed without DC switch. For inverters designed with DC switch, the model name should be GW3648C-ES.
*6: FOR AUSTRALIA ONLY. Model GW5048D-ES inverters are designed without DC switch. For inverters designed with DC switch, the model name should be GW5048C-ES.
*1. Under off-grid mode, then battery capacity should be more than 100Ah.
*2: When there is no battery connected, inverter starts feeding in only if string voltage is higher than 200V.
*:Please visit GoodWe website for the latest certificates.